

# GSC ENERGY PRO PIPE

## FLOW CHARACTERISTICS

<i>DR15.5</i>	<i>139 PSI</i>	<i>3.00" - 12.00"</i>
<i>DR11</i>	<i>202 PSI</i>	<i>0.75" - 12.00"</i>
<i>DR9</i>	<i>252 PSI</i>	<i>1.00" - 8.00"</i>

# GSC ENERGY PRO PIPE

1.00" IPS PE4710 DR9 252 PSI

## PIPE INFORMATION

CELL CLASS: PE445574C  
 PIPE SIZE: 1.00"  
 OD: 1.315"  
 ID: 1.005"  
 DR: 9  
 MAX VEL: 15  
 VOL/100 FT: 4.27 GAL

## FLUID INFORMATION

TEMP (F): 40.0  
 FREEZE PT (F): 32.0  
 VISC (CP): 1.55  
 DENSITY 62.43  
 WATER - NO INHIBITORS

## \*\* CONVERSION RULE OF THUMB #1 \*\*

WATER AND ANTIFREEZE  
 SOLUTION AT 25° F

20% PROPLENE GLYCOL: 1.36  
 20% METHANOL ALCOHOL: 1.25

## UBEND PURGING GPM

FT/SEC = GPM x # Bores/Circuit = Purging GPM

2.05 = 5.25 x # B/C = Purging GPM

3.03 = 8.25 x # B/C = Purging GPM

4.00 = 10.50 x # B/C = Purging GPM

5.07 = 13.00 x # B/C = Purging GPM

\* Head Loss is determined by using  
 the Darcy-Weisbach Equation\*  
 $(HL)f = f(L/D)((V*V)/2g)$

<b>GPM</b>	<b>VELOCITY (ft/sec)</b>	<b>RE NUMBER</b>	<b>HL* (ft/100 ft)</b>	<b>PD (lbs/100 ft)</b>
0.50	0.20	998	0.04	0.02
1.00	0.39	1,996	0.09	0.04
1.50	0.59	2,994	0.13	0.06
2.00	0.78	3,992	0.18	0.08
2.50	0.98	4,990	0.65	0.28
3.00	1.17	5,988	0.90	0.39
3.50	1.37	6,986	1.18	0.51
4.00	1.56	7,984	1.49	0.64
4.50	1.76	8,982	1.83	0.79
5.00	1.95	9,980	2.20	0.95
5.50	2.15	10,978	2.31	1.00
6.00	2.34	11,976	2.70	1.17
6.50	2.54	12,974	3.12	1.35
7.00	2.73	13,972	3.56	1.54
7.50	2.93	14,971	4.03	1.75
8.00	3.12	15,969	4.53	1.96
8.50	3.32	16,967	5.05	2.19
9.00	3.51	17,965	5.59	2.42
9.50	3.71	18,963	6.16	2.67
10.00	3.90	19,961	6.76	2.93
11.00	4.29	21,957	8.02	3.47
12.00	4.68	23,953	9.37	4.06
13.00	5.07	25,949	10.82	4.69
14.00	5.46	27,945	12.36	5.36
15.00	5.86	29,941	13.99	6.06
16.00	6.25	31,937	15.71	6.81
17.00	6.64	33,933	17.52	7.59
18.00	7.03	35,929	19.42	8.41
19.00	7.42	37,925	21.40	9.27
20.00	7.81	39,921	23.47	10.17



Geothermal Supply Company, Inc  
 106 Cherry Street Horse Cave, KY 42749  
 Ph: 270-786-3010 Fax: 270-786-4136  
 Email : info@geothermalsupply.com  
 www.geothermalsupply.com

# GSC ENERGY PRO PIPE

1.25" IPS PE4710 DR9 252 PSI

## PIPE INFORMATION

CELL CLASS: PE445574C  
 PIPE SIZE: 1.25"  
 OD: 1.660"  
 ID: 1.269"  
 DR: 9  
 MAX VEL: 15  
 VOL/100 FT: 6.81 GAL

## FLUID INFORMATION

TEMP (F): 40.0  
 FREEZE PT (F): 32.0  
 VISC (CP): 1.55  
 DENSITY 62.43  
 WATER - NO INHIBITORS

## \*\* CONVERSION RULE OF THUMB #1 \*\*

WATER AND ANTIFREEZE  
 SOLUTION AT 25° F

20% PROPLENE GLYCOL: 1.36  
 20% METHANOL ALCOHOL: 1.25

## UBEND PURGING GPM

FT/SEC = GPM x # Bores/Circuit = Purging GPM

2.08 = 8.50 x # B/C = Purging GPM

3.06 = 12.50 x # B/C = Purging GPM

4.04 = 16.50 x # B/C = Purging GPM

5.02 = 20.50 x # B/C = Purging GPM

\* Head Loss is determined by using  
 the Darcy-Weisbach Equation\*  
 $(HL)f = f(L/D)((V*V)/2g)$

<b>GPM</b>	<b>VELOCITY (ft/sec)</b>	<b>RE NUMBER</b>	<b>HL* (ft/100 ft)</b>	<b>PD (lbs/100 ft)</b>
1.50	0.37	2,371	0.05	0.02
2.00	0.49	3,161	0.07	0.03
2.50	0.61	3,951	0.09	0.04
3.00	0.73	4,741	0.30	0.13
3.50	0.86	5,532	0.39	0.17
4.00	0.98	6,322	0.49	0.21
4.50	1.10	7,112	0.60	0.26
5.00	1.22	7,902	0.72	0.31
5.50	1.35	8,693	0.86	0.37
6.00	1.47	9,483	1.00	0.43
6.50	1.59	10,273	1.02	0.44
7.00	1.71	11,063	1.16	0.50
7.50	1.84	11,854	1.32	0.57
8.00	1.96	12,644	1.48	0.64
8.50	2.08	13,434	1.65	0.71
9.00	2.20	14,224	1.83	0.79
9.50	2.32	15,015	2.01	0.87
10.00	2.45	15,805	2.21	0.96
10.50	2.57	16,595	2.41	1.04
11.00	2.69	17,385	2.62	1.13
12.00	2.94	18,966	3.06	1.33
13.00	3.18	20,546	3.53	1.53
14.00	3.43	22,127	4.04	1.75
15.00	3.67	23,707	4.57	1.98
16.00	3.92	25,288	5.13	2.22
17.00	4.16	26,868	5.72	2.48
18.00	4.40	28,449	6.34	2.75
19.00	4.65	30,029	6.98	3.03
20.00	4.89	31,610	7.66	3.32
21.00	5.14	33,190	8.36	3.62



Geothermal Supply Company, Inc  
 106 Cherry Street Horse Cave, KY 42749  
 Ph: 270-786-3010 Fax: 270-786-4136  
 Email : info@geothermalsupply.com  
 www.geothermalsupply.com

# GSC ENERGY PRO PIPE

1.50" IPS PE4710 DR9 252 PSI

## PIPE INFORMATION

CELL CLASS: PE445574C  
 PIPE SIZE: 1.50"  
 OD: 1.900"  
 ID: 1.452"  
 DR: 9  
 MAX VEL: 15  
 VOL/100 FT: 8.91 GAL

## FLUID INFORMATION

TEMP (F): 40.0  
 FREEZE PT (F): 32.0  
 VISC (CP): 1.55  
 DENSITY 62.43  
 WATER - NO INHIBITORS

## \*\* CONVERSION RULE OF THUMB #1 \*\*

WATER AND ANTIFREEZE  
 SOLUTION AT 25° F

20% PROYPLENE GLYCOL: 1.36  
 20% METHANOL ALCOHOL: 1.25

\* Head Loss is determined by using  
 the Darcy-Weisbach Equation\*  
 $(HL)f = f(L/D)((V*V)/2g)$

<b>GPM</b>	<b>VELOCITY (ft/sec)</b>	<b>RE NUMBER</b>	<b>HL* (ft/100 ft)</b>	<b>PD (lbs/100 ft)</b>
2.00	0.37	2,763	0.04	0.02
3.00	0.56	4,145	0.16	0.07
4.00	0.75	5,526	0.26	0.11
5.00	0.94	6,908	0.38	0.17
6.00	1.12	8,290	0.53	0.23
7.00	1.31	9,671	0.69	0.30
8.00	1.50	11,053	0.78	0.34
9.00	1.68	12,434	0.96	0.42
10.00	1.87	13,816	1.16	0.50
11.00	2.06	15,197	1.37	0.60
12.00	2.24	16,579	1.61	0.70
13.00	2.43	17,961	1.85	0.80
14.00	2.62	19,342	2.12	0.92
15.00	2.81	20,724	2.40	1.04
16.00	2.99	22,105	2.69	1.17
17.00	3.18	23,487	3.00	1.30
18.00	3.37	24,869	3.32	1.44
19.00	3.55	26,250	3.66	1.59
20.00	3.74	27,632	4.02	1.74
21.00	3.93	29,013	4.38	1.90
23.00	4.30	31,776	5.16	2.24
25.00	4.68	34,540	6.00	2.60
27.00	5.05	37,303	6.89	2.98
29.00	5.42	40,066	7.83	3.39
31.00	5.80	42,829	8.83	3.83
33.00	6.17	45,592	9.88	4.28
35.00	6.55	48,355	10.99	4.76
37.00	6.92	51,119	12.14	5.26
39.00	7.29	53,882	13.35	5.79
41.00	7.67	56,645	14.61	6.33



Geothermal Supply Company, Inc  
 106 Cherry Street Horse Cave, KY 42749  
 Ph: 270-786-3010 Fax: 270-786-4136  
 Email : info@geothermalsupply.com  
 www.geothermalsupply.com

# GSC ENERGY PRO PIPE

2.00" IPS PE4710 DR9 252 PSI

## PIPE INFORMATION

CELL CLASS: PE445574C  
 PIPE SIZE: 2.00"  
 OD: 2.375"  
 ID: 1.816"  
 DR: 9  
 MAX VEL: 15  
 VOL/100 FT: 13.92 GAL

## FLUID INFORMATION

TEMP (F): 40.0  
 FREEZE PT (F): 32.0  
 VISC (CP): 1.55  
 DENSITY 62.43  
 WATER - NO INHIBITORS

## \*\* CONVERSION RULE OF THUMB #1 \*\*

WATER AND ANTIFREEZE  
 SOLUTION AT 25° F

20% PROYPLENE GLYCOL: 1.36  
 20% METHANOL ALCOHOL: 1.25

\* Head Loss is determined by using  
 the Darcy-Weisbach Equation\*  
 $(HL)f = f(L/D)((V*V)/2g)$

<b>GPM</b>	<b>VELOCITY (ft/sec)</b>	<b>RE NUMBER</b>	<b>HL* (ft/100 ft)</b>	<b>PD (lbs/100 ft)</b>
2.50	0.30	2,764	0.02	0.01
4.00	0.48	4,422	0.09	0.04
5.50	0.66	6,081	0.16	0.07
7.00	0.84	7,739	0.24	0.10
8.50	1.02	9,397	0.34	0.15
10.00	1.20	11,056	0.40	0.17
11.50	1.38	12,714	0.51	0.22
13.00	1.56	14,372	0.64	0.28
14.50	1.74	16,031	0.77	0.34
16.00	1.92	17,689	0.92	0.40
17.50	2.10	19,347	1.09	0.47
19.00	2.28	21,006	1.26	0.55
20.50	2.45	22,664	1.44	0.62
22.00	2.63	24,322	1.64	0.71
23.50	2.81	25,981	1.84	0.80
25.00	2.99	27,639	2.06	0.89
26.50	3.17	29,297	2.29	0.99
28.00	3.35	30,956	2.52	1.09
29.50	3.53	32,614	2.77	1.20
31.00	3.71	34,273	3.03	1.31
34.00	4.07	37,589	3.58	1.55
37.00	4.43	40,906	4.17	1.81
40.00	4.79	44,223	4.79	2.08
43.00	5.15	47,539	5.46	2.37
46.00	5.51	50,856	6.17	2.67
49.00	5.87	54,173	6.91	2.99
52.00	6.23	57,489	7.69	3.33
55.00	6.59	60,806	8.51	3.69
58.00	6.95	64,123	9.36	4.06
61.00	7.30	67,440	10.25	4.44



Geothermal Supply Company, Inc  
 106 Cherry Street Horse Cave, KY 42749  
 Ph: 270-786-3010 Fax: 270-786-4136  
 Email : info@geothermalsupply.com  
 www.geothermalsupply.com

# GSC ENERGY PRO PIPE

3.00" IPS PE4710 DR9 252 PSI

## PIPE INFORMATION

CELL CLASS: PE445574C  
 PIPE SIZE: 3.00"  
 OD: 3.500"  
 ID: 2.676"  
 DR: 9  
 MAX VEL: 15  
 VOL/100 FT: 30.23 GAL

## FLUID INFORMATION

TEMP (F): 40.0  
 FREEZE PT (F): 32.0  
 VISC (CP): 1.55  
 DENSITY 62.43  
 WATER - NO INHIBITORS

## \*\* CONVERSION RULE OF THUMB #1 \*\*

WATER AND ANTIFREEZE  
 SOLUTION AT 25° F

20% PROYPLENE GLYCOL: 1.36  
 20% METHANOL ALCOHOL: 1.25

\* Head Loss is determined by using  
 the Darcy-Weisbach Equation\*  
 $(HL)f = f(L/D)((V*V)/2g)$

<b>GPM</b>	<b>VELOCITY (ft/sec)</b>	<b>RE NUMBER</b>	<b>HL* (ft/100 ft)</b>	<b>PD (lbs/100 ft)</b>
15.00	0.83	11,253	0.13	0.06
20.00	1.10	15,004	0.21	0.09
25.00	1.38	18,754	0.32	0.14
30.00	1.65	22,505	0.44	0.19
35.00	1.93	26,256	0.59	0.25
40.00	2.21	30,007	0.75	0.32
45.00	2.48	33,758	0.92	0.40
50.00	2.76	37,509	1.11	0.48
55.00	3.03	41,260	1.32	0.57
60.00	3.31	45,011	1.55	0.67
65.00	3.58	48,761	1.79	0.77
70.00	3.86	52,512	2.04	0.88
75.00	4.14	56,263	2.31	1.00
80.00	4.41	60,014	2.60	1.12
85.00	4.69	63,765	2.90	1.25
90.00	4.96	67,516	3.21	1.39
95.00	5.24	71,267	3.54	1.53
100.00	5.51	75,018	3.88	1.68
105.00	5.79	78,769	4.24	1.84
110.00	6.06	82,519	4.61	2.00
120.00	6.62	90,021	5.39	2.34
130.00	7.17	97,523	6.23	2.70
140.00	7.72	105,025	7.12	3.09
150.00	8.27	112,526	8.07	3.50
160.00	8.82	120,028	9.07	3.93
170.00	9.37	127,530	10.12	4.38
180.00	9.92	135,032	11.22	4.86
190.00	10.48	142,534	12.37	5.36
200.00	11.03	150,035	13.58	5.88
210.00	11.58	157,537	14.83	6.43



Geothermal Supply Company, Inc  
 106 Cherry Street Horse Cave, KY 42749  
 Ph: 270-786-3010 Fax: 270-786-4136  
 Email : info@geothermalsupply.com  
 www.geothermalsupply.com

# GSC ENERGY PRO PIPE

4.00" IPS PE4710 DR9 252 PSI

## PIPE INFORMATION

CELL CLASS: PE445574C  
 PIPE SIZE: 4.00"  
 OD: 4.500"  
 ID: 3.440"  
 DR: 9  
 MAX VEL: 15  
 VOL/100 FT: 49.98 GAL

## FLUID INFORMATION

TEMP (F): 40.0  
 FREEZE PT (F): 32.0  
 VISC (CP): 1.55  
 DENSITY 62.43  
 WATER - NO INHIBITORS

## \*\* CONVERSION RULE OF THUMB #1 \*\*

WATER AND ANTIFREEZE  
 SOLUTION AT 25° F

20% PROYPLENE GLYCOL: 1.36  
 20% METHANOL ALCOHOL: 1.25

\* Head Loss is determined by using  
 the Darcy-Weisbach Equation\*  
 $(HL)f = f(L/D)((V*V)/2g)$

<b>GPM</b>	<b>VELOCITY (ft/sec)</b>	<b>RE NUMBER</b>	<b>HL* (ft/100 ft)</b>	<b>PD (lbs/100 ft)</b>
25.50	0.85	14,877	0.10	0.04
31.00	1.03	18,086	0.14	0.06
36.50	1.22	21,295	0.19	0.08
42.00	1.40	24,504	0.24	0.11
47.50	1.58	27,713	0.30	0.13
53.00	1.77	30,921	0.37	0.16
58.50	1.95	34,130	0.44	0.19
64.00	2.13	37,339	0.52	0.23
69.50	2.32	40,548	0.60	0.26
75.00	2.50	43,757	0.69	0.30
80.50	2.68	46,966	0.79	0.34
86.00	2.87	50,174	0.88	0.38
91.50	3.05	53,383	0.99	0.43
97.00	3.23	56,592	1.10	0.48
102.50	3.42	59,801	1.21	0.53
108.00	3.60	63,010	1.33	0.58
113.50	3.78	66,219	1.46	0.63
119.00	3.97	69,427	1.59	0.69
124.50	4.15	72,636	1.72	0.75
130.00	4.34	75,845	1.86	0.81
141.00	4.70	82,263	2.16	0.93
152.00	5.07	88,680	2.47	1.07
163.00	5.44	95,098	2.80	1.21
174.00	5.80	101,516	3.15	1.37
185.00	6.17	107,933	3.52	1.53
196.00	6.54	114,351	3.91	1.69
207.00	6.90	120,769	4.31	1.87
218.00	7.27	127,186	4.74	2.05
229.00	7.64	133,604	5.18	2.24
240.00	8.00	140,022	5.64	2.44



Geothermal Supply Company, Inc  
 106 Cherry Street Horse Cave, KY 42749  
 Ph: 270-786-3010 Fax: 270-786-4136  
 Email : info@geothermalsupply.com  
 www.geothermalsupply.com

# GSC ENERGY PRO PIPE

6.00" IPS PE4710 DR9 252 PSI

## PIPE INFORMATION

CELL CLASS: PE445574C  
 PIPE SIZE: 6.00"  
 OD: 6.625"  
 ID: 5.064"  
 DR: 9  
 MAX VEL: 15  
 VOL/100 FT: 108.34 GAL

## FLUID INFORMATION

TEMP (F): 40.0  
 FREEZE PT (F): 32.0  
 VISC (CP): 1.55  
 DENSITY 62.43  
 WATER - NO INHIBITORS

## \*\* CONVERSION RULE OF THUMB #1 \*\*

WATER AND ANTIFREEZE  
 SOLUTION AT 25° F

20% PROYPLENE GLYCOL: 1.36  
 20% METHANOL ALCOHOL: 1.25

\* Head Loss is determined by using  
 the Darcy-Weisbach Equation\*  
 $(HL)f = f(L/D)((V*V)/2g)$

<b>GPM</b>	<b>VELOCITY (ft/sec)</b>	<b>RE NUMBER</b>	<b>HL* (ft/100 ft)</b>	<b>PD (lbs/100 ft)</b>
100.00	1.54	39,627	0.18	0.08
120.00	1.85	47,552	0.25	0.11
140.00	2.15	55,478	0.33	0.14
160.00	2.46	63,403	0.42	0.18
180.00	2.77	71,329	0.52	0.23
200.00	3.08	79,254	0.63	0.27
220.00	3.38	87,179	0.75	0.33
240.00	3.69	95,105	0.88	0.38
260.00	4.00	103,030	1.01	0.44
280.00	4.31	110,956	1.16	0.50
300.00	4.62	118,881	1.31	0.57
320.00	4.92	126,806	1.48	0.64
340.00	5.23	134,732	1.65	0.71
360.00	5.54	142,657	1.83	0.79
380.00	5.85	150,583	2.01	0.87
400.00	6.15	158,508	2.21	0.96
420.00	6.46	166,433	2.41	1.05
440.00	6.77	174,359	2.63	1.14
460.00	7.08	182,284	2.85	1.23
480.00	7.38	190,210	3.07	1.33
520.00	8.00	206,060	3.55	1.54
560.00	8.62	221,911	4.07	1.76
600.00	9.23	237,762	4.61	2.00
640.00	9.85	253,613	5.18	2.24
680.00	10.46	269,464	5.78	2.51
720.00	11.08	285,315	6.41	2.78
760.00	11.69	301,165	7.08	3.07
800.00	12.31	317,016	7.77	3.37
840.00	12.92	332,867	8.49	3.68
880.00	13.54	348,718	9.24	4.00



Geothermal Supply Company, Inc  
 106 Cherry Street Horse Cave, KY 42749  
 Ph: 270-786-3010 Fax: 270-786-4136  
 Email : info@geothermalsupply.com  
 www.geothermalsupply.com



# GSC ENERGY PRO PIPE

8.00" IPS PE4710 DR9 252 PSI

## PIPE INFORMATION

CELL CLASS: PE445574C  
 PIPE SIZE: 8.00"  
 OD: 8.625"  
 ID: 6.593"  
 DR: 9  
 MAX VEL: 15  
 VOL/100 FT: 183.64 GAL

## FLUID INFORMATION

TEMP (F): 40.0  
 FREEZE PT (F): 32.0  
 VISC (CP): 1.55  
 DENSITY 62.43  
 WATER - NO INHIBITORS

## \*\* CONVERSION RULE OF THUMB #1 \*\*

WATER AND ANTIFREEZE  
 SOLUTION AT 25° F

20% PROYPLENE GLYCOL: 1.36  
 20% METHANOL ALCOHOL: 1.25

\* Head Loss is determined by using  
 the Darcy-Weisbach Equation\*  
 $(HL)f = f(L/D)((V*V)/2g)$

<b>GPM</b>	<b>VELOCITY (ft/sec)</b>	<b>RE NUMBER</b>	<b>HL* (ft/100 ft)</b>	<b>PD (lbs/100 ft)</b>
200.00	1.82	60,873	0.18	0.08
220.00	2.00	66,960	0.21	0.09
240.00	2.18	73,047	0.25	0.11
260.00	2.36	79,135	0.29	0.12
280.00	2.54	85,222	0.33	0.14
300.00	2.72	91,309	0.37	0.16
320.00	2.90	97,397	0.42	0.18
340.00	3.09	103,484	0.46	0.20
360.00	3.27	109,571	0.51	0.22
380.00	3.45	115,658	0.57	0.25
400.00	3.63	121,746	0.62	0.27
420.00	3.81	127,833	0.68	0.29
440.00	3.99	133,920	0.74	0.32
460.00	4.17	140,008	0.80	0.35
480.00	4.36	146,095	0.86	0.37
500.00	4.54	152,182	0.93	0.40
520.00	4.72	158,269	1.00	0.43
540.00	4.90	164,357	1.07	0.46
560.00	5.08	170,444	1.14	0.49
580.00	5.26	176,531	1.22	0.53
620.00	5.63	188,706	1.37	0.60
660.00	5.99	200,880	1.54	0.67
700.00	6.35	213,055	1.71	0.74
740.00	6.72	225,230	1.89	0.82
780.00	7.08	237,404	2.08	0.90
820.00	7.44	249,579	2.28	0.99
860.00	7.81	261,753	2.49	1.08
900.00	8.17	273,928	2.70	1.17
940.00	8.53	286,102	2.92	1.27
980.00	8.89	298,277	3.15	1.37



Geothermal Supply Company, Inc  
 106 Cherry Street Horse Cave, KY 42749  
 Ph: 270-786-3010 Fax: 270-786-4136  
 Email : info@geothermalsupply.com  
 www.geothermalsupply.com

# GSC ENERGY PRO PIPE

0.75" IPS PE4710 DR11 202 PSI

## PIPE INFORMATION

CELL CLASS: PE445574C  
 PIPE SIZE: 0.75"  
 OD: 1.050"  
 ID: 0.860"  
 DR: 11  
 MAX VEL: 15  
 VOL/100 FT: 3.02 GAL

## FLUID INFORMATION

TEMP (F): 40.0  
 FREEZE PT (F): 32.0  
 VISC (CP): 1.55  
 DENSITY 62.43  
 WATER - NO INHIBITORS

## \*\* CONVERSION RULE OF THUMB #1 \*\*

WATER AND ANTIFREEZE  
 SOLUTION AT 25° F

20% PROPLENE GLYCOL: 1.36  
 20% METHANOL ALCOHOL: 1.25

## UBEND PURGING GPM

FT/SEC = GPM x # Bores/Circuit = Purging GPM

2.07 = 3.75 x # B/C = Purging GPM

3.04 = 5.50 x # B/C = Purging GPM

4.01 = 7.25 x # B/C = Purging GPM

5.11 = 9.25 x # B/C = Purging GPM

\* Head Loss is determined by using  
 the Darcy-Weisbach Equation\*  
 $(HL)f = f(L/D)((V*V)/2g)$

<b>GPM</b>	<b>VELOCITY (ft/sec)</b>	<b>RE NUMBER</b>	<b>HL* (ft/100 ft)</b>	<b>PD (lbs/100 ft)</b>
0.75	0.41	1,781	0.13	0.06
1.00	0.55	2,374	0.18	0.08
1.25	0.69	2,968	0.22	0.10
1.50	0.83	3,562	0.27	0.12
1.75	0.97	4,155	0.80	0.35
2.00	1.10	4,749	1.01	0.44
2.25	1.24	5,342	1.24	0.54
2.50	1.38	5,936	1.49	0.65
2.75	1.52	6,530	1.46	0.76
3.00	1.66	7,123	2.05	0.89
3.25	1.80	7,717	2.36	1.02
3.50	1.93	8,310	2.68	1.16
3.75	2.07	8,904	3.03	1.13
4.00	2.21	9,498	3.39	1.47
4.25	2.35	10,091	3.35	1.45
4.50	2.49	10,685	3.71	1.61
4.75	2.62	11,278	4.09	1.77
5.00	2.76	11,872	4.48	1.94
5.25	2.90	12,466	4.89	2.12
5.50	3.04	13,059	5.32	2.30
6.00	3.31	14,246	6.21	2.69
6.50	3.59	15,434	7.17	3.11
7.00	3.87	16,621	8.19	3.55
7.50	4.14	17,808	9.27	4.02
8.00	4.42	18,995	10.41	4.51
8.50	4.69	20,182	11.60	5.03
9.00	4.97	21,370	12.85	5.57
9.50	5.25	22,557	14.16	6.14
10.00	5.52	23,744	15.53	6.73
10.50	5.80	24,931	16.95	7.34



Geothermal Supply Company, Inc  
 106 Cherry Street Horse Cave, KY 42749  
 Ph: 270-786-3010 Fax: 270-786-4136  
 Email : info@geothermalsupply.com  
 www.geothermalsupply.com

# GSC ENERGY PRO PIPE

1.00" IPS PE4710 DR11 202 PSI

## PIPE INFORMATION

CELL CLASS: PE445574C  
 PIPE SIZE: 1.00"  
 OD: 1.315"  
 ID: 1.062"  
 DR: 11  
 MAX VEL: 15  
 VOL/100 FT: 4.71 GAL

## FLUID INFORMATION

TEMP (F): 40.0  
 FREEZE PT (F): 32.0  
 VISC (CP): 1.55  
 DENSITY 62.43  
 WATER - NO INHIBITORS

## \*\* CONVERSION RULE OF THUMB #1 \*\*

WATER AND ANTIFREEZE  
 SOLUTION AT 25° F

20% PROYLENE GLYCOL: 1.36  
 20% METHANOL ALCOHOL: 1.25

## UBEND PURGING GPM

FT/SEC = GPM x # Bores/Circuit = Purging GPM

2.03 = 5.75 x # B/C = Purging GPM

3.00 = 8.50 x # B/C = Purging GPM

4.07 = 11.50 x # B/C = Purging GPM

5.13 = 14.50 x # B/C = Purging GPM

\* Head Loss is determined by using  
 the Darcy-Weisbach Equation\*  
 $(HL)f = f(L/D)((V*V)/2g)$

<b>GPM</b>	<b>VELOCITY (ft/sec)</b>	<b>RE NUMBER</b>	<b>HL* (ft/100 ft)</b>	<b>PD (lbs/100 ft)</b>
0.50	0.18	950	0.04	0.02
1.00	0.35	1,900	0.07	0.03
1.50	0.53	2,849	0.11	0.05
2.00	0.71	3,799	0.15	0.06
2.50	0.88	4,749	0.52	0.22
3.00	1.06	5,699	0.71	0.31
3.50	1.24	6,648	0.93	0.40
4.00	1.41	7,598	1.17	0.51
4.50	1.59	8,548	1.44	0.63
5.00	1.77	9,498	1.74	0.75
5.50	1.94	10,447	1.82	0.79
6.00	2.12	11,397	2.13	0.92
6.50	2.30	12,347	2.46	1.07
7.00	2.47	13,297	2.81	1.22
7.50	2.65	14,246	3.18	1.38
8.00	2.83	15,196	3.57	1.55
8.50	3.00	16,146	3.98	1.72
9.00	3.18	17,096	4.41	1.91
9.50	3.36	18,045	4.86	2.11
10.00	3.53	18,995	5.33	2.31
11.00	3.89	20,895	6.32	2.74
12.00	4.24	22,794	7.39	3.20
13.00	4.60	24,694	8.53	3.70
14.00	4.95	26,593	9.75	4.22
15.00	5.30	28,493	11.03	4.78
16.00	5.66	30,392	12.39	5.37
17.00	6.01	32,292	13.81	5.99
18.00	6.36	34,191	15.31	6.63
19.00	6.72	36,091	16.87	7.31
20.00	7.07	37,990	18.50	8.02



Geothermal Supply Company, Inc  
 106 Cherry Street Horse Cave, KY 42749  
 Ph: 270-786-3010 Fax: 270-786-4136  
 Email : info@geothermalsupply.com  
 www.geothermalsupply.com

# GSC ENERGY PRO PIPE

1.25" IPS PE4710 DR11 202 PSI

## PIPE INFORMATION

CELL CLASS: PE445574C  
 PIPE SIZE: 1.25"  
 OD: 1.660"  
 ID: 1.340"  
 DR: 11  
 MAX VEL: 15  
 VOL/100 FT: 7.52 GAL

## FLUID INFORMATION

TEMP (F): 40.0  
 FREEZE PT (F): 32.0  
 VISC (CP): 1.55  
 DENSITY 62.43  
 WATER - NO INHIBITORS

## \*\* CONVERSION RULE OF THUMB #1 \*\*

WATER AND ANTIFREEZE  
 SOLUTION AT 25° F

20% PROYLENE GLYCOL: 1.36  
 20% METHANOL ALCOHOL: 1.25

## UBEND PURGING GPM

FT/SEC = GPM x # Bores/Circuit = Purging GPM

2.05 = 9.25 x # B/C = Purging GPM

3.10 = 14.00 x # B/C = Purging GPM

4.10 = 18.50 x # B/C = Purging GPM

5.09 = 23.00 x # B/C = Purging GPM

\* Head Loss is determined by using  
 the Darcy-Weisbach Equation\*  
 $(HL)f = f(L/D)((V*V)/2g)$

<b>GPM</b>	<b>VELOCITY (ft/sec)</b>	<b>RE NUMBER</b>	<b>HL* (ft/100 ft)</b>	<b>PD (lbs/100 ft)</b>
1.50	0.33	2,256	0.04	0.02
2.00	0.44	3,007	0.06	0.02
2.50	0.55	3,759	0.07	0.03
3.00	0.66	4,511	0.23	0.10
3.50	0.78	5,263	0.31	0.13
4.00	0.89	6,015	0.39	0.17
4.50	1.00	6,767	0.48	0.21
5.00	1.11	7,518	0.57	0.25
5.50	1.22	8,270	0.68	0.29
6.00	1.33	9,022	0.79	0.34
6.50	1.44	9,774	0.91	0.39
7.00	1.55	10,526	0.92	0.40
7.50	1.66	11,278	1.04	0.45
8.00	1.77	12,029	1.17	0.50
8.50	1.88	12,781	1.30	0.56
9.00	1.99	13,533	1.44	0.62
9.50	2.10	14,285	1.59	0.69
10.00	2.22	15,037	1.74	0.75
10.50	2.33	15,789	1.90	0.82
11.00	2.44	16,540	2.06	0.89
12.00	2.66	18,044	2.41	1.04
13.00	2.88	19,548	2.78	1.21
14.00	3.10	21,051	3.18	1.38
15.00	3.32	22,555	3.60	1.56
16.00	3.54	24,059	4.04	1.75
17.00	3.77	25,562	4.50	1.95
18.00	3.99	27,066	4.99	2.16
19.00	4.21	28,570	5.50	2.38
20.00	4.43	30,073	6.03	2.61
21.00	4.65	31,577	6.58	2.85



Geothermal Supply Company, Inc  
 106 Cherry Street Horse Cave, KY 42749  
 Ph: 270-786-3010 Fax: 270-786-4136  
 Email : info@geothermalsupply.com  
 www.geothermalsupply.com

# GSC ENERGY PRO PIPE

1.50" IPS PE4710 DR11 202 PSI

## PIPE INFORMATION

CELL CLASS: PE445574C  
 PIPE SIZE: 1.500"  
 OD: 1.900"  
 ID: 1.534"  
 DR: 11  
 MAX VEL: 15  
 VOL/100 FT: 9.85 GAL

## FLUID INFORMATION

TEMP (F): 40.0  
 FREEZE PT (F): 32.0  
 VISC (CP): 1.55  
 DENSITY 62.43  
 WATER - NO INHIBITORS

## \*\* CONVERSION RULE OF THUMB #1 \*\*

WATER AND ANTIFREEZE  
 SOLUTION AT 25° F

20% PROYPLENE GLYCOL: 1.36  
 20% METHANOL ALCOHOL: 1.25

\* Head Loss is determined by using  
 the Darcy-Weisbach Equation\*  
 $(HL)f = f(L/D)((V*V)/2g)$

<b>GPM</b>	<b>VELOCITY (ft/sec)</b>	<b>RE NUMBER</b>	<b>HL* (ft/100 ft)</b>	<b>PD (lbs/100 ft)</b>
2.00	0.34	2,628	0.03	0.01
3.00	0.51	3,942	0.05	0.02
4.00	0.68	5,256	0.20	0.09
5.00	0.85	6,570	0.30	0.13
6.00	1.01	7,884	0.41	0.18
7.00	1.18	9,198	0.54	0.24
8.00	1.35	10,512	0.61	0.26
9.00	1.52	11,826	0.75	0.33
10.00	1.69	13,140	0.91	0.39
11.00	1.86	14,454	1.08	0.47
12.00	2.03	15,768	1.26	0.55
13.00	2.20	17,082	1.46	0.63
14.00	2.37	18,396	1.67	0.72
15.00	2.54	19,710	1.88	0.82
16.00	2.71	21,024	2.12	0.92
17.00	2.88	22,338	2.36	1.02
18.00	3.04	23,652	2.61	1.13
19.00	3.21	24,966	2.88	1.25
20.00	3.38	26,280	3.16	1.37
21.00	3.55	27,594	3.45	1.49
23.00	3.89	30,222	4.06	1.76
25.00	4.23	32,850	4.72	2.04
27.00	4.57	35,478	5.42	2.35
29.00	4.91	38,106	6.16	2.67
31.00	5.24	40,734	6.94	3.01
33.00	5.58	43,363	7.77	3.37
35.00	5.92	45,991	8.64	3.74
37.00	6.26	48,619	9.55	4.14
39.00	6.60	51,247	10.50	4.55
41.00	6.94	53,875	11.48	4.98



Geothermal Supply Company, Inc  
 106 Cherry Street Horse Cave, KY 42749  
 Ph: 270-786-3010 Fax: 270-786-4136  
 Email : info@geothermalsupply.com  
 www.geothermalsupply.com

# GSC ENERGY PRO PIPE

2.00" IPS PE4710 DR11 202 PSI

## PIPE INFORMATION

CELL CLASS: PE445574C  
 PIPE SIZE: 2.00"  
 OD: 2.375"  
 ID: 1.917"  
 DR: 11  
 MAX VEL: 15  
 VOL/100 FT: 15.40 GAL

## FLUID INFORMATION

TEMP (F): 40.0  
 FREEZE PT (F): 32.0  
 VISC (CP): 1.55  
 DENSITY 62.43  
 WATER - NO INHIBITORS

## \*\* CONVERSION RULE OF THUMB #1 \*\*

WATER AND ANTIFREEZE  
 SOLUTION AT 25° F

20% PROYPLENE GLYCOL: 1.36  
 20% METHANOL ALCOHOL: 1.25

\* Head Loss is determined by using  
 the Darcy-Weisbach Equation\*  
 $(HL)f = f(L/D)((V*V)/2g)$

<b>GPM</b>	<b>VELOCITY (ft/sec)</b>	<b>RE NUMBER</b>	<b>HL* (ft/100 ft)</b>	<b>PD (lbs/100 ft)</b>
2.50	0.27	2,627	0.02	0.01
4.00	0.43	4,204	0.07	0.03
5.50	0.60	5,780	0.12	0.05
7.00	0.76	7,357	0.19	0.08
8.50	0.92	8,933	0.26	0.11
10.00	1.08	10,509	0.31	0.14
11.50	1.24	12,086	0.40	0.17
13.00	1.41	13,662	0.40	0.22
14.50	1.57	15,239	0.61	0.26
16.00	1.73	16,815	0.73	0.31
17.50	1.89	18,391	0.85	0.37
19.00	2.06	19,968	0.99	0.43
20.50	2.22	21,544	1.13	0.49
22.00	2.38	23,121	1.28	0.56
23.50	2.54	24,697	1.45	0.63
25.00	2.71	26,274	1.62	0.70
26.50	2.87	27,850	1.79	0.78
28.00	3.03	29,426	1.98	0.86
29.50	3.19	31,003	2.17	0.94
31.00	3.35	32,579	2.38	1.03
34.00	3.68	35,732	2.81	1.22
37.00	4.00	38,885	3.27	1.42
40.00	4.33	42,038	3.76	1.63
43.00	4.65	45,191	4.28	1.86
46.00	4.98	48,343	4.83	2.09
49.00	5.30	51,496	5.42	2.35
52.00	5.63	54,649	6.03	2.61
55.00	5.95	57,802	6.67	2.89
58.00	6.28	60,955	7.34	3.18
61.00	6.60	64,107	8.04	3.48



Geothermal Supply Company, Inc  
 106 Cherry Street Horse Cave, KY 42749  
 Ph: 270-786-3010 Fax: 270-786-4136  
 Email : info@geothermalsupply.com  
 www.geothermalsupply.com

# GSC ENERGY PRO PIPE

3.00" IPS PE4710 DR11 202 PSI

## PIPE INFORMATION

CELL CLASS: PE445574C  
 PIPE SIZE: 3.00"  
 OD: 3.500"  
 ID: 2.825"  
 DR: 11  
 MAX VEL: 15  
 VOL/100 FT: 33.47 GAL

## FLUID INFORMATION

TEMP (F): 40.0  
 FREEZE PT (F): 32.0  
 VISC (CP): 1.55  
 DENSITY 62.43  
 WATER - NO INHIBITORS

## \*\* CONVERSION RULE OF THUMB #1 \*\*

WATER AND ANTIFREEZE  
 SOLUTION AT 25° F

20% PROYPLENE GLYCOL: 1.36  
 20% METHANOL ALCOHOL: 1.25

\* Head Loss is determined by using  
 the Darcy-Weisbach Equation\*  
 $(HL)f = f(L/D)((V*V)/2g)$

<b>GPM</b>	<b>VELOCITY (ft/sec)</b>	<b>RE NUMBER</b>	<b>HL* (ft/100 ft)</b>	<b>PD (lbs/100 ft)</b>
15.00	0.75	10,695	0.10	0.04
20.00	1.00	14,260	0.17	0.07
25.00	1.25	17,825	0.25	0.11
30.00	1.49	21,389	0.35	0.15
35.00	1.74	24,954	0.46	0.20
40.00	1.99	28,519	0.58	0.25
45.00	2.24	32,084	0.72	0.31
50.00	2.49	35,649	0.87	0.38
55.00	2.74	39,214	1.04	0.45
60.00	2.99	42,779	1.21	0.52
65.00	3.24	46,344	1.40	0.61
70.00	3.49	49,909	1.60	0.69
75.00	3.74	53,474	1.81	0.78
80.00	3.98	57,039	2.03	0.88
85.00	4.23	60,603	2.27	0.98
90.00	4.48	64,168	2.51	1.09
95.00	4.73	67,733	2.77	1.20
100.00	4.98	71,298	3.04	1.32
105.00	5.23	74,863	3.32	1.44
110.00	5.48	78,428	3.61	1.56
120.00	5.98	85,558	4.22	1.83
130.00	6.47	92,688	4.88	2.11
140.00	6.97	99,817	5.58	2.42
150.00	7.47	106,947	6.32	2.74
160.00	7.97	114,077	7.10	3.08
170.00	8.47	121,207	7.92	3.43
180.00	8.96	128,337	8.79	3.81
190.00	9.46	135,467	9.69	4.20
200.00	9.96	142,596	10.63	4.61
210.00	10.46	149,726	11.61	5.03



Geothermal Supply Company, Inc  
 106 Cherry Street Horse Cave, KY 42749  
 Ph: 270-786-3010 Fax: 270-786-4136  
 Email : info@geothermalsupply.com  
 www.geothermalsupply.com

# GSC ENERGY PRO PIPE

4.00" IPS PE4710 DR11 202 PSI

## PIPE INFORMATION

CELL CLASS: PE445574C  
 PIPE SIZE: 4.00"  
 OD: 4.500"  
 ID: 3.633"  
 DR: 11  
 MAX VEL: 15  
 VOL/100 FT: 55.31 GAL

## FLUID INFORMATION

TEMP (F): 40.0  
 FREEZE PT (F): 32.0  
 VISC (CP): 1.55  
 DENSITY 62.43  
 WATER - NO INHIBITORS

## \*\* CONVERSION RULE OF THUMB #1 \*\*

WATER AND ANTIFREEZE  
 SOLUTION AT 25° F

20% PROYPLENE GLYCOL: 1.36  
 20% METHANOL ALCOHOL: 1.25

\* Head Loss is determined by using  
 the Darcy-Weisbach Equation\*  
 $(HL)f = f(L/D)((V*V)/2g)$

<b>GPM</b>	<b>VELOCITY (ft/sec)</b>	<b>RE NUMBER</b>	<b>HL* (ft/100 ft)</b>	<b>PD (lbs/100 ft)</b>
25.00	0.75	13,865	0.08	0.03
30.50	0.92	16,915	0.11	0.05
36.00	1.08	19,965	0.14	0.06
41.50	1.25	23,015	0.19	0.08
47.00	1.42	26,065	0.23	0.10
52.50	1.58	29,116	0.29	0.12
58.00	1.75	32,166	0.34	0.15
63.50	1.91	35,216	0.40	0.17
69.00	2.08	38,266	0.47	0.20
74.50	2.24	41,317	0.54	0.23
80.00	2.41	44,367	0.61	0.26
85.50	2.58	47,417	0.69	0.30
91.00	2.74	50,467	0.77	0.33
96.50	2.91	53,517	0.85	0.37
102.00	3.07	56,568	0.94	0.41
107.50	3.24	59,618	1.04	0.45
113.00	3.40	62,668	1.13	0.49
118.50	3.57	65,718	1.24	0.54
124.00	3.74	68,768	1.34	0.58
129.50	3.90	71,819	1.45	0.63
140.50	4.23	77,919	1.68	0.73
151.50	4.56	84,020	1.92	0.83
162.50	4.90	90,120	2.18	0.95
173.50	5.23	96,220	2.46	1.06
184.50	5.56	102,321	2.75	1.19
195.50	5.89	108,421	3.05	1.32
206.50	6.22	114,522	3.37	1.46
217.50	6.55	120,622	3.70	1.60
228.50	6.89	126,723	4.04	1.75
239.50	7.22	132,823	4.40	1.91



Geothermal Supply Company, Inc  
 106 Cherry Street Horse Cave, KY 42749  
 Ph: 270-786-3010 Fax: 270-786-4136  
 Email : info@geothermalsupply.com  
 www.geothermalsupply.com



# GSC ENERGY PRO PIPE

6.00" IPS PE4710 DR11 202 PSI

## PIPE INFORMATION

CELL CLASS: PE445574C  
 PIPE SIZE: 6.00"  
 OD: 6.625"  
 ID: 5.348"  
 DR: 11  
 MAX VEL: 15  
 VOL/100 FT: 119.90 GAL

## FLUID INFORMATION

TEMP (F): 40.0  
 FREEZE PT (F): 32.0  
 VISC (CP): 1.55  
 DENSITY 62.43  
 WATER - NO INHIBITORS

## \*\* CONVERSION RULE OF THUMB #1 \*\*

WATER AND ANTIFREEZE  
 SOLUTION AT 25° F

20% PROYPLENE GLYCOL: 1.36  
 20% METHANOL ALCOHOL: 1.25

\* Head Loss is determined by using  
 the Darcy-Weisbach Equation\*  
 $(HL)f = f(L/D)((V*V)/2g)$

<b>GPM</b>	<b>VELOCITY (ft/sec)</b>	<b>RE NUMBER</b>	<b>HL* (ft/100 ft)</b>	<b>PD (lbs/100 ft)</b>
100.00	1.39	37,668	0.14	0.06
120.00	1.67	45,202	0.20	0.09
140.00	1.95	52,735	0.26	0.11
160.00	2.22	60,269	0.33	0.14
180.00	2.50	67,802	0.41	0.18
200.00	2.78	75,336	0.50	0.21
220.00	3.06	82,870	0.59	0.25
240.00	3.34	90,403	0.69	0.30
260.00	3.61	97,937	0.79	0.34
280.00	3.89	105,470	0.91	0.39
300.00	4.17	113,004	1.03	0.45
320.00	4.45	120,537	1.16	0.50
340.00	4.73	128,071	1.26	0.56
360.00	5.00	135,605	1.43	0.62
380.00	5.28	143,138	1.58	0.68
400.00	5.56	150,672	1.73	0.75
420.00	5.84	158,205	1.89	0.82
440.00	6.12	165,739	2.06	0.89
460.00	6.39	173,273	2.23	0.97
480.00	6.67	180,806	2.41	1.04
520.00	7.23	195,873	2.79	1.21
560.00	7.78	210,941	3.19	1.38
600.00	8.34	226,008	3.61	1.56
640.00	8.90	241,075	4.06	1.76
680.00	9.45	256,142	4.53	1.96
720.00	10.01	271,209	5.03	2.18
760.00	10.56	286,277	5.54	2.40
800.00	11.12	301,344	6.08	2.64
840.00	11.68	316,411	6.65	2.88
880.00	12.23	331,478	7.23	3.13



Geothermal Supply Company, Inc  
 106 Cherry Street Horse Cave, KY 42749  
 Ph: 270-786-3010 Fax: 270-786-4136  
 Email : info@geothermalsupply.com  
 www.geothermalsupply.com

# GSC ENERGY PRO PIPE

8.00" IPS PE4710 DR11 202 PSI

## PIPE INFORMATION

CELL CLASS: PE445574C  
 PIPE SIZE: 8.00"  
 OD: 8.625"  
 ID: 6.963"  
 DR: 11  
 MAX VEL: 15  
 VOL/100 FT: 203.19 GAL

## FLUID INFORMATION

TEMP (F): 40.0  
 FREEZE PT (F): 32.0  
 VISC (CP): 1.55  
 DENSITY 62.43  
 WATER - NO INHIBITORS

## \*\* CONVERSION RULE OF THUMB #1 \*\*

WATER AND ANTIFREEZE  
 SOLUTION AT 25° F

20% PROYPLENE GLYCOL: 1.36  
 20% METHANOL ALCOHOL: 1.25

\* Head Loss is determined by using  
 the Darcy-Weisbach Equation\*  
 $(HL)f = f(L/D)((V*V)/2g)$

<b>GPM</b>	<b>VELOCITY (ft/sec)</b>	<b>RE NUMBER</b>	<b>HL* (ft/100 ft)</b>	<b>PD (lbs/100 ft)</b>
200.00	1.64	57,871	0.14	0.06
220.00	1.80	63,658	0.17	0.07
240.00	1.97	69,445	0.19	0.08
260.00	2.13	75,232	0.22	0.10
280.00	2.30	81,019	0.26	0.11
300.00	2.46	86,807	0.29	0.13
320.00	2.62	92,594	0.33	0.14
340.00	2.79	98,381	0.36	0.16
360.00	2.95	104,168	0.40	0.17
380.00	3.12	109,955	0.44	0.19
400.00	3.28	115,742	0.49	0.21
420.00	3.45	121,529	0.53	0.23
440.00	3.61	127,316	0.58	0.25
460.00	3.77	133,103	0.63	0.27
480.00	3.94	138,891	0.68	0.29
500.00	4.10	144,678	0.73	0.32
520.00	4.27	150,465	0.78	0.34
540.00	4.43	156,252	0.84	0.36
560.00	4.59	162,039	0.90	0.39
580.00	4.76	167,826	0.95	0.41
620.00	5.09	179,400	1.08	0.47
660.00	5.41	190,974	1.21	0.52
700.00	5.74	202,549	1.34	0.58
740.00	6.07	214,123	1.48	0.64
780.00	6.40	225,697	1.63	0.71
820.00	6.73	237,271	1.79	0.77
860.00	7.05	248,846	1.95	0.84
900.00	7.38	260,420	2.12	0.92
940.00	7.71	271,994	2.29	0.99
980.00	8.04	283,568	2.47	1.07



Geothermal Supply Company, Inc  
 106 Cherry Street Horse Cave, KY 42749  
 Ph: 270-786-3010 Fax: 270-786-4136  
 Email : info@geothermalsupply.com  
 www.geothermalsupply.com

# GSC ENERGY PRO PIPE

10.00" IPS PE4710 DR11 202 PSI

## PIPE INFORMATION

CELL CLASS: PE445574C  
 PIPE SIZE: 10.00"  
 OD: 10.750"  
 ID: 8.678"  
 DR: 11  
 MAX VEL: 15  
 VOL/100 FT: 315.67 GAL

## FLUID INFORMATION

TEMP (F): 40.0  
 FREEZE PT (F): 32.0  
 VISC (CP): 1.55  
 DENSITY 62.43  
 WATER - NO INHIBITORS

## \*\* CONVERSION RULE OF THUMB #1 \*\*

WATER AND ANTIFREEZE  
 SOLUTION AT 25° F

20% PROYPLENE GLYCOL: 1.36  
 20% METHANOL ALCOHOL: 1.25

\* Head Loss is determined by using  
 the Darcy-Weisbach Equation\*  
 $(HL)f = f(L/D)((V*V)/2g)$

<b>GPM</b>	<b>VELOCITY (ft/sec)</b>	<b>RE NUMBER</b>	<b>HL* (ft/100 ft)</b>	<b>PD (lbs/100 ft)</b>
300.00	1.58	69,645	0.10	0.04
350.00	1.85	81,252	0.13	0.06
400.00	2.11	92,859	0.17	0.07
450.00	2.38	104,467	0.21	0.09
500.00	2.64	116,074	0.25	0.11
550.00	2.90	127,682	0.30	0.13
600.00	3.17	139,289	0.35	0.15
650.00	3.43	150,897	0.41	0.18
700.00	3.70	162,504	0.46	0.20
750.00	3.96	174,112	0.53	0.23
800.00	4.22	185,719	0.59	0.26
850.00	4.49	197,326	0.66	0.29
900.00	4.75	208,934	0.73	0.32
950.00	5.02	220,541	0.81	0.35
1000.00	5.28	232,149	0.89	0.38
1050.00	5.54	243,756	0.97	0.42
1100.00	5.81	255,364	1.05	0.46
1150.00	6.07	266,971	1.14	0.50
1200.00	6.34	278,578	1.23	0.54
1250.00	6.60	290,186	1.33	0.58
1300.00	6.86	301,793	1.43	0.62
1400.00	7.39	325,008	1.63	0.71
1500.00	7.92	348,223	1.85	0.80
1600.00	8.45	371,438	2.08	0.90
1700.00	8.98	394,653	2.33	1.01
1800.00	9.50	417,868	2.58	1.12
1900.00	10.03	441,083	2.85	1.23
2000.00	10.56	464,297	3.13	1.35
2100.00	11.09	487,512	3.42	1.48
2200.00	11.62	510,727	3.72	1.61



Geothermal Supply Company, Inc  
 106 Cherry Street Horse Cave, KY 42749  
 Ph: 270-786-3010 Fax: 270-786-4136  
 Email : info@geothermalsupply.com  
 www.geothermalsupply.com

# GSC ENERGY PRO PIPE

12.00" IPS PE4710 DR11 202 PSI

## PIPE INFORMATION

CELL CLASS: PE445574C  
 PIPE SIZE: 12.00"  
 OD: 12.750"  
 ID: 10.293"  
 DR: 11  
 MAX VEL: 15  
 VOL/100 FT: 444.01 GAL

## FLUID INFORMATION

TEMP (F): 40.0  
 FREEZE PT (F): 32.0  
 VISC (CP): 1.55  
 DENSITY 62.43  
 WATER - NO INHIBITORS

## \*\* CONVERSION RULE OF THUMB #1 \*\*

WATER AND ANTIFREEZE  
 SOLUTION AT 25° F

20% PROYPLENE GLYCOL: 1.36  
 20% METHANOL ALCOHOL: 1.25

\* Head Loss is determined by using  
 the Darcy-Weisbach Equation\*  
 $(HL)f = f(L/D)((V*V)/2g)$

<b>GPM</b>	<b>VELOCITY (ft/sec)</b>	<b>RE NUMBER</b>	<b>HL* (ft/100 ft)</b>	<b>PD (lbs/100 ft)</b>
400.00	1.50	78,297	0.07	0.03
500.00	1.88	97,871	0.11	0.05
600.00	2.25	117,445	0.15	0.07
700.00	2.63	137,019	0.20	0.09
800.00	3.00	156,594	0.26	0.11
900.00	3.38	176,168	0.32	0.14
1000.00	3.75	195,742	0.39	0.17
1100.00	4.13	215,316	0.46	0.20
1200.00	4.50	234,890	0.54	0.24
1300.00	4.88	254,465	0.63	0.27
1400.00	5.26	274,039	0.72	0.31
1500.00	5.63	293,613	0.81	0.35
1600.00	6.01	313,187	0.92	0.40
1700.00	6.38	332,761	1.02	0.44
1800.00	6.76	352,336	1.13	0.49
1900.00	7.13	371,910	1.25	0.54
2000.00	7.51	391,484	1.37	0.60
2100.00	7.88	411,058	1.50	0.65
2200.00	8.26	430,632	1.63	0.71
2300.00	8.63	450,207	1.77	0.77
2400.00	9.01	469,781	1.91	0.83
2500.00	9.38	489,355	2.06	0.89
2600.00	9.76	508,929	2.21	0.96
2700.00	10.13	528,503	2.37	1.03
2800.00	10.51	548,078	2.53	1.10
3000.00	11.26	587,226	2.87	1.25
3200.00	12.01	626,374	3.23	1.40
3400.00	12.76	665,523	3.61	1.56
3600.00	13.51	704,671	4.01	1.74
3800.00	14.26	743,819	4.42	1.92



Geothermal Supply Company, Inc  
 106 Cherry Street Horse Cave, KY 42749  
 Ph: 270-786-3010 Fax: 270-786-4136  
 Email : info@geothermalsupply.com  
 www.geothermalsupply.com

# GSC ENERGY PRO PIPE

3.00" IPS PE4710 DR15.5 139 PSI

## PIPE INFORMATION

CELL CLASS: PE445574C  
 PIPE SIZE: 3.00"  
 OD: 3.500"  
 ID: 3.021"  
 DR: 15.5  
 MAX VEL: 15  
 VOL/100 FT: 37.90 GAL

## FLUID INFORMATION

TEMP (F): 40.0  
 FREEZE PT (F): 32.0  
 VISC (CP): 1.55  
 DENSITY 62.43  
 WATER - NO INHIBITORS

## \*\* CONVERSION RULE OF THUMB #1 \*\*

WATER AND ANTIFREEZE  
 SOLUTION AT 25° F

20% PROYPLENE GLYCOL: 1.36  
 20% METHANOL ALCOHOL: 1.25

\* Head Loss is determined by using  
 the Darcy-Weisbach Equation\*  
 $(HL)f = f(L/D)((V*V)/2g)$

<b>GPM</b>	<b>VELOCITY (ft/sec)</b>	<b>RE NUMBER</b>	<b>HL* (ft/100 ft)</b>	<b>PD (lbs/100 ft)</b>
15.00	0.66	10,049	0.07	0.03
20.00	0.88	13,399	0.13	0.05
25.00	1.10	16,749	0.19	0.08
30.00	1.32	20,098	0.26	0.11
35.00	1.54	23,448	0.34	0.15
40.00	1.76	26,798	0.43	0.19
45.00	1.98	30,147	0.54	0.23
50.00	2.20	33,497	0.65	0.28
55.00	2.42	36,847	0.77	0.33
60.00	2.64	40,196	0.90	0.39
65.00	2.86	43,546	1.04	0.45
70.00	3.08	46,896	1.19	0.51
75.00	3.30	50,246	1.34	0.58
80.00	3.52	53,595	1.51	0.65
85.00	3.74	56,945	1.68	0.73
90.00	3.96	60,295	1.86	0.81
95.00	4.18	63,644	2.06	0.89
100.00	4.40	66,994	2.25	0.98
105.00	4.62	70,344	2.46	1.07
110.00	4.84	73,694	2.68	1.16
120.00	5.28	80,393	3.13	1.36
130.00	5.75	87,092	3.62	1.57
140.00	6.16	93,792	4.14	1.79
150.00	6.60	100,491	4.69	2.03
160.00	7.04	107,191	5.26	2.28
170.00	7.47	113,890	5.87	2.55
180.00	7.91	120,589	6.51	2.82
190.00	8.35	127,289	7.18	3.11
200.00	8.79	133,988	7.88	3.41
210.00	9.23	140,688	8.61	3.73



Geothermal Supply Company, Inc  
 106 Cherry Street Horse Cave, KY 42749  
 Ph: 270-786-3010 Fax: 270-786-4136  
 Email : info@geothermalsupply.com  
 www.geothermalsupply.com

# GSC ENERGY PRO PIPE

4.00" IPS PE4710 DR15.5 139 PSI

## PIPE INFORMATION

CELL CLASS: PE445574C  
 PIPE SIZE: 4.00"  
 OD: 4.500"  
 ID: 3.885"  
 DR: 15.5  
 MAX VEL: 15  
 VOL/100 FT: 62.69 GAL

## FLUID INFORMATION

TEMP (F): 40.0  
 FREEZE PT (F): 32.0  
 VISC (CP): 1.55  
 DENSITY 62.43  
 WATER - NO INHIBITORS

## \*\* CONVERSION RULE OF THUMB #1 \*\*

WATER AND ANTIFREEZE  
 SOLUTION AT 25° F

20% PROYPLENE GLYCOL: 1.36  
 20% METHANOL ALCOHOL: 1.25

\* Head Loss is determined by using  
 the Darcy-Weisbach Equation\*  
 $(HL)f = f(L/D)((V*V)/2g)$

<b>GPM</b>	<b>VELOCITY (ft/sec)</b>	<b>RE NUMBER</b>	<b>HL* (ft/100 ft)</b>	<b>PD (lbs/100 ft)</b>
25.50	0.68	13,283	0.06	0.03
31.00	0.82	16,148	0.08	0.04
36.50	0.97	19,013	0.11	0.05
42.00	1.12	21,878	0.14	0.06
47.50	1.26	24,743	0.18	0.08
53.00	1.41	27,608	0.21	0.09
58.50	1.56	30,473	0.26	0.11
64.00	1.70	33,338	0.30	0.13
69.50	1.85	36,203	0.35	0.15
75.00	1.99	39,068	0.40	0.17
80.50	2.14	41,934	0.46	0.20
86.00	2.29	44,799	0.51	0.22
91.50	2.43	47,664	0.57	0.25
97.00	2.58	50,529	0.64	0.28
102.50	2.72	53,394	0.70	0.31
108.00	2.87	56,259	0.77	0.34
113.50	3.02	59,124	0.85	0.37
119.00	3.16	61,989	0.92	0.40
124.50	3.31	64,854	1.00	0.43
130.00	3.46	67,719	1.08	0.47
141.00	3.75	73,449	1.25	0.54
152.00	4.04	79,179	1.43	0.62
163.00	4.33	84,909	1.62	0.70
174.00	4.63	90,639	1.83	0.79
185.00	4.92	96,369	2.04	0.88
196.00	5.21	102,099	2.27	0.98
207.00	5.50	107,829	2.50	1.08
218.00	5.80	113,559	2.75	1.19
229.00	6.09	119,289	3.00	1.30
240.00	6.38	125,019	3.27	1.42



Geothermal Supply Company, Inc  
 106 Cherry Street Horse Cave, KY 42749  
 Ph: 270-786-3010 Fax: 270-786-4136  
 Email : info@geothermalsupply.com  
 www.geothermalsupply.com

# GSC ENERGY PRO PIPE

6.00" IPS PE4710 DR15.5 139 PSI

## PIPE INFORMATION

CELL CLASS: PE445574C  
 PIPE SIZE: 6.00"  
 OD: 6.625"  
 ID: 5.719"  
 DR: 15.5  
 MAX VEL: 15  
 VOL/100 FT: 135.88 GAL

## FLUID INFORMATION

TEMP (F): 40.0  
 FREEZE PT (F): 32.0  
 VISC (CP): 1.55  
 DENSITY 62.43  
 WATER - NO INHIBITORS

## \*\* CONVERSION RULE OF THUMB #1 \*\*

WATER AND ANTIFREEZE  
 SOLUTION AT 25° F

20% PROYPLENE GLYCOL: 1.36  
 20% METHANOL ALCOHOL: 1.25

\* Head Loss is determined by using  
 the Darcy-Weisbach Equation\*  
 $(HL)f = f(L/D)((V*V)/2g)$

<b>GPM</b>	<b>VELOCITY (ft/sec)</b>	<b>RE NUMBER</b>	<b>HL* (ft/100 ft)</b>	<b>PD (lbs/100 ft)</b>
100.00	1.23	35,383	0.11	0.05
120.00	1.47	42,460	0.15	0.06
140.00	1.72	49,537	0.19	0.08
160.00	1.96	56,614	0.25	0.11
180.00	2.21	63,690	0.30	0.13
200.00	2.45	70,767	0.37	0.16
220.00	2.70	77,844	0.44	0.19
240.00	2.94	84,920	0.51	0.22
260.00	3.19	91,997	0.59	0.25
280.00	3.43	99,074	0.67	0.29
300.00	3.68	106,150	0.76	0.33
320.00	3.93	113,227	0.86	0.37
340.00	4.17	120,304	0.96	0.41
360.00	4.42	127,381	1.06	0.46
380.00	4.66	134,457	1.17	0.51
400.00	4.91	141,534	1.28	0.56
420.00	5.15	148,611	1.40	0.61
440.00	5.40	155,687	1.52	0.66
460.00	5.64	162,764	1.65	0.72
480.00	5.89	169,841	1.78	0.77
520.00	6.38	183,994	2.06	0.89
560.00	6.87	198,147	2.36	1.02
600.00	7.36	212,301	2.67	1.16
640.00	7.85	226,454	3.00	1.30
680.00	8.34	240,608	3.35	1.45
720.00	8.83	254,761	3.72	1.61
760.00	9.32	268,914	4.10	1.78
800.00	9.81	283,068	4.50	1.95
840.00	10.30	297,221	4.92	2.13
880.00	10.79	311,375	5.35	2.32



Geothermal Supply Company, Inc  
 106 Cherry Street Horse Cave, KY 42749  
 Ph: 270-786-3010 Fax: 270-786-4136  
 Email : info@geothermalsupply.com  
 www.geothermalsupply.com

# GSC ENERGY PRO PIPE

8.00" IPS PE4710 DR15.5 139 PSI

## PIPE INFORMATION

CELL CLASS: PE445574C  
 PIPE SIZE: 8.00"  
 OD: 8.625"  
 ID: 7.445"  
 DR: 15.5  
 MAX VEL: 15  
 VOL/100 FT: 230.30 GAL

## FLUID INFORMATION

TEMP (F): 40.0  
 FREEZE PT (F): 32.0  
 VISC (CP): 1.55  
 DENSITY 62.43  
 WATER - NO INHIBITORS

## \*\* CONVERSION RULE OF THUMB #1 \*\*

WATER AND ANTIFREEZE  
 SOLUTION AT 25° F

20% PROYPLENE GLYCOL: 1.36  
 20% METHANOL ALCOHOL: 1.25

\* Head Loss is determined by using  
 the Darcy-Weisbach Equation\*  
 $(HL)f = f(L/D)((V*V)/2g)$

<b>GPM</b>	<b>VELOCITY (ft/sec)</b>	<b>RE NUMBER</b>	<b>HL* (ft/100 ft)</b>	<b>PD (lbs/100 ft)</b>
200.00	1.45	54,359	0.10	0.04
220.00	1.59	59,794	0.12	0.05
240.00	1.74	65,230	0.14	0.06
260.00	1.88	70,666	0.17	0.07
280.00	2.03	76,102	0.19	0.08
300.00	2.17	81,538	0.21	0.09
320.00	2.32	86,974	0.24	0.10
340.00	2.46	92,410	0.27	0.12
360.00	2.61	97,845	0.30	0.13
380.00	2.75	103,281	0.33	0.14
400.00	2.89	108,717	0.36	0.16
420.00	3.04	114,153	0.39	0.17
440.00	3.18	119,589	0.43	0.19
460.00	3.33	125,025	0.46	0.20
480.00	3.47	130,461	0.50	0.22
500.00	3.62	135,896	0.54	0.23
520.00	3.76	141,332	0.58	0.25
540.00	3.91	146,768	0.62	0.27
560.00	4.05	152,204	0.66	0.29
580.00	4.20	157,640	0.71	0.31
600.00	4.35	163,076	0.75	0.33
620.00	4.49	168,512	0.80	0.35
640.00	4.64	173,948	0.84	0.37
660.00	4.78	179,383	0.89	0.39
680.00	4.93	184,819	0.93	0.41
700.00	5.07	190,255	0.99	0.43
720.00	5.22	195,691	1.03	0.45
740.00	5.36	201,127	1.10	0.48
760.00	5.51	206,563	1.16	0.50
780.00	5.64	211,998	1.21	0.52
800.00	5.79	217,434	1.27	0.54
820.00	5.93	222,870	1.32	0.57
840.00	6.08	228,306	1.38	0.59
860.00	6.22	233,742	1.44	0.62
880.00	6.37	239,178	1.50	0.64
900.00	6.51	244,614	1.57	0.68
920.00	6.66	250,050	1.63	0.70
940.00	6.80	255,485	1.69	0.73
960.00	6.95	260,921	1.75	0.75
980.00	7.09	266,357	1.83	0.79



Geothermal Supply Company, Inc  
 106 Cherry Street Horse Cave, KY 42749  
 Ph: 270-786-3010 Fax: 270-786-4136  
 Email : info@geothermalsupply.com  
 www.geothermalsupply.com



# GSC ENERGY PRO PIPE

10.00" IPS PE4710 DR15.5 139 PSI

## PIPE INFORMATION

CELL CLASS: PE445574C  
 PIPE SIZE: 10.00"  
 OD: 10.750"  
 ID: 9.280"  
 DR: 15.5  
 MAX VEL: 15  
 VOL/100 FT: 357.60 GAL

## FLUID INFORMATION

TEMP (F): 40.0  
 FREEZE PT (F): 32.0  
 VISC (CP): 1.55  
 DENSITY 62.43  
 WATER - NO INHIBITORS

## \*\* CONVERSION RULE OF THUMB #1 \*\*

WATER AND ANTIFREEZE  
 SOLUTION AT 25° F

20% PROYPLENE GLYCOL: 1.36  
 20% METHANOL ALCOHOL: 1.25

\* Head Loss is determined by using  
 the Darcy-Weisbach Equation\*  
 $(HL)f = f(L/D)((V*V)/2g)$

<b>GPM</b>	<b>VELOCITY (ft/sec)</b>	<b>RE NUMBER</b>	<b>HL* (ft/100 ft)</b>	<b>PD (lbs/100 ft)</b>
300.00	1.40	65,434	0.07	0.03
350.00	1.63	76,340	0.10	0.04
400.00	1.86	87,245	0.13	0.05
450.00	2.10	98,151	0.15	0.07
500.00	2.33	109,057	0.19	0.08
550.00	2.56	119,963	0.22	0.10
600.00	2.80	130,868	0.26	0.11
650.00	3.03	141,774	0.30	0.13
700.00	3.26	152,680	0.34	0.15
750.00	3.50	163,585	0.39	0.17
800.00	3.73	174,491	0.44	0.19
850.00	3.96	185,397	0.49	0.21
900.00	4.19	196,302	0.54	0.24
950.00	4.43	207,208	0.60	0.26
1000.00	4.66	218,114	0.66	0.28
1050.00	4.89	229,019	0.72	0.31
1100.00	5.13	239,925	0.78	0.34
1150.00	5.36	250,831	0.85	0.37
1200.00	5.59	261,736	0.91	0.40
1250.00	5.83	272,642	0.98	0.43
1350.00	6.29	294,453	1.13	0.49
1450.00	6.76	316,265	1.29	0.56
1550.00	7.22	338,076	1.46	0.63
1650.00	7.69	359,888	1.63	0.71
1750.00	8.16	381,699	1.82	0.79
1850.00	8.62	403,510	2.01	0.87
1950.00	9.09	425,322	2.21	0.96
2050.00	9.55	447,133	2.42	1.05
2150.00	10.02	468,944	2.64	1.14
2250.00	10.49	490,756	2.87	1.24



Geothermal Supply Company, Inc  
 106 Cherry Street Horse Cave, KY 42749  
 Ph: 270-786-3010 Fax: 270-786-4136  
 Email : info@geothermalsupply.com  
 www.geothermalsupply.com

# GSC ENERGY PRO PIPE

12.00" IPS PE4710 DR15.5 139 PSI

## PIPE INFORMATION

CELL CLASS: PE445574C  
 PIPE SIZE: 12.00"  
 OD: 12.750"  
 ID: 11.006"  
 DR: 15.5  
 MAX VEL: 15  
 VOL/100 FT: 503.06 GAL

## FLUID INFORMATION

TEMP (F): 40.0  
 FREEZE PT (F): 32.0  
 VISC (CP): 1.55  
 DENSITY 62.43  
 WATER - NO INHIBITORS

## \*\* CONVERSION RULE OF THUMB #1 \*\*

WATER AND ANTIFREEZE  
 SOLUTION AT 25° F

20% PROYPLENE GLYCOL: 1.36  
 20% METHANOL ALCOHOL: 1.25

\* Head Loss is determined by using  
 the Darcy-Weisbach Equation\*  
 $(HL)f = f(L/D)((V*V)/2g)$

<b>GPM</b>	<b>VELOCITY (ft/sec)</b>	<b>RE NUMBER</b>	<b>HL* (ft/100 ft)</b>	<b>PD (lbs/100 ft)</b>
400.00	1.33	73,558	0.06	0.02
500.00	1.66	91,948	0.08	0.04
600.00	1.99	110,338	0.11	0.05
700.00	2.32	128,727	0.15	0.07
800.00	2.65	147,117	0.19	0.08
900.00	2.98	165,506	0.24	0.10
1000.00	3.31	183,896	0.29	0.13
1100.00	3.64	202,286	0.34	0.15
1200.00	3.98	220,675	0.40	0.17
1300.00	4.31	239,065	0.47	0.20
1400.00	4.64	257,454	0.53	0.23
1500.00	4.97	275,844	0.60	0.26
1600.00	5.30	294,233	0.68	0.29
1700.00	5.63	312,623	0.76	0.33
1800.00	5.96	331,013	0.84	0.36
1900.00	6.29	349,402	0.93	0.40
2000.00	6.63	367,792	1.02	0.44
2100.00	6.96	386,181	1.11	0.48
2200.00	7.29	404,571	1.21	0.52
2300.00	7.62	422,961	1.31	0.57
2500.00	8.28	459,740	1.53	0.66
2700.00	8.95	496,519	1.76	0.76
2900.00	9.61	533,298	2.00	0.87
3100.00	10.27	570,077	2.26	0.98
3300.00	10.93	606,857	2.53	1.10
3500.00	11.60	643,636	2.82	1.22
3700.00	12.26	680,415	3.12	1.35
3900.00	12.92	717,194	3.43	1.49
4100.00	13.58	753,973	3.76	1.63
4300.00	14.25	790,752	4.10	1.78



Geothermal Supply Company, Inc  
 106 Cherry Street Horse Cave, KY 42749  
 Ph: 270-786-3010 Fax: 270-786-4136  
 Email : info@geothermalsupply.com  
 www.geothermalsupply.com